

Fault Zone – Power Circuit

The power circuit refers to all of the conductors and connections that exist from the point at which the testing starts through to the connections at the motor. It can include circuit breakers, fuses, contactors, overloads, disconnects, and lug connections. Research on industrial power distribution systems has shown that connectors and conductors are the source of 46% of the faults reducing motor efficiency.


The MCEMAX powered by MCEGold™ provides a unique advantage to test the power circuit and all the associated components. Many times a motor, although initially in perfect health, is installed into a faulty power circuit. This causes problems like voltage imbalances, current imbalances, sequence currents, etc. As these problems become more severe, the horsepower rating of the motor drops, causing temperatures to increase and insulation damage to occur. It is important to evaluate the resistance and inductance of a motor circuit once a motor is installed for service. High imbalances of voltage, current, resistance, or inductance could indicate problems with the motor or power circuit. Identifying minor imbalances early will eliminate catastrophic failures and headaches later.

Test Date	9/20/1996	3/23/1998	3/29/1999	5/23/2000	5/23/2000	1/23/2001
% Res. Imbalance	0.18	0.63	0.18	3.64	3.09	0.27

Trend Phase-to Phase resistance over time. If an out of tolerance condition occurs MCEGold will alert you.

All three phases of current are calculated and displayed. You are immediately alerted to any over current or imbalance condition

Phase	Voltage	Current
Phase 1	480.76	102.02
Phase 2	480.76	104.07
Phase 3	480.37	101.12



Fault Zone	Test Type	Date	Condition Code
Power Circuit	Voltage Imbalance (%)	Not Tested	Caution
Power Circuit	Resistive Imbalance (%)	3.25 12/7/2005 2:20:22 PM	Caution
Power Quality	Current THD Ph-Ph (%)	Not Tested	Not Tested
Power Quality	Current THD (%)	Not Tested	Not Tested
Power Quality	HVF (%)	Not Tested	Not Tested
Insulation	Stator RTG (Meg)	1900.00 12/7/2005 2:20:22 PM	Good
Insulation	PI	3.49 12/7/2005 2:08:48 PM	Good
Insulation	CTG (pF)	64000.00 12/7/2005 2:20:22 PM	Good
Stator	Imp. Imbalance (%)	Not Tested	Not Tested
Stator	Inductive Imbalance (%)	14.07 12/7/2005 2:20:22 PM	Severe
Rotor	Fp Amplitude (Delta dB)	Not Tested	Not Tested
Rotor	Eccentricity	Not Tested	Not Tested
Air Gap	Peak One (Delta dB)	Not Tested	Insufficient Data
Air Gap	Peak Two (Delta dB)	Not Tested	Insufficient Data
Air Gap	Peak Three (Delta dB)	Not Tested	Insufficient Data
Air Gap	Peak Four (Delta dB)	Not Tested	Insufficient Data
Air Gap	RIC (Eccentricity)	False 12/7/2005 12:41:19 PM	Insufficient Data

The MCEMAX powered by MCEGold provides a Fault Zone Report, which is a one-page summary of the test results relevant to the six fault zones. The Fault Zone Report may be reached directly through the Fault Zones icon on the toolbar.